ASSESSMENT OF INDOOR AIR POLLUTION AND HEALTH COMPLAINTS AMONG OFFICE EMPLOYEES

Žanna Martinsone,

Mārīte Ārija Baķe and Maija Eglīte

Institute of Occupational Safety and Environmental Health,
Riga Stradins University, Latvia

International Conference on Occupational Health and Safety: From policies to practice Rīga, December 6-7, 2012







Introduction

■ There are not set main priorities for indoor air pollution in the non-idustrial workplaces (offices), while ~ 35% of employees are working in offices in Latvia.

■ Indoor air quality is an important public health factor that influences persons' health and well-being (dry skin, irritation of mucuous membrane, dry cough, allergic rashes etc.).

■ The insufficient information about the new risk factor — nanoparticles in the non-industrial workplaces (offices).



The aim of study

■ To assess the non-industrial workplace indoor air quality indicators and the health complaints of employees.





Methodes and materials (1)

■ The study was realised from October, 2009 till September, 2011.

- This report include following parts:
 - **»measures** of indoor air quality in offices;
 - **»survey** of office workers.



Methodes and materials (2)

- During study 24 premises of 10 offices were assessed (measures were done):
 - mostly, open type offices (2- 35 persons per room).
 - the all measurements were tested during full working day (8 hours) in winter and spring period.
- The indoor climate was characterized by parameters
 - air temperature, humidity and air flow,
 - also carbon dioxide.

For measures were used multifunctional equipment TESTO 400.



Methodes and materials (3)

- The air quality was tested by modern equipment, it depends on the aim of measures:
 - VOC's and aldehydes were tested by Gas chromatography (Varian 3800) and High-Performance Liquid Chromatography (Waters Alliance 2695);
 - non-organic gases (NO₂, SO₂) also O₃ were tested by spectrophotometry (Varian Cary 50);
 - particles were tested by
 - ✓ count (P-Track Ultrafine Particle Counter) and
 - ✓ surface area concentration (AeroTrack9000).



Methodes and materials (4)

■ The **exposure index** was used to assess the risk of chemical pollution to office — workers health.

■ EI = results of measures/acceptable limit.

■ If EI >1, it is mean, that high risk to health exist.



Methodes and materials (5)

■ Questionnaire (Örebro-MM40) for assessment of health complaints and indoor air quality.


■ Questionnaire consist of 4 parts: general information, description of work process, health status description and indoor air quality.



RESULTS



Results— measures of particles (1)



Size of particles (nanoparticles) from 40,58 nm to 69,91 nm – agglomerates.




Results— measures of particles (2)

- The study of dust particle surface area evaluation of indoor air <u>A-alveolar fraction</u> (from 10 250 nm) indicates that "the cleanest or the reference room" mean was $6.0 \,\mu\text{m}^2/\text{cm}^3$, but the highest $55.5 \,\mu\text{m}^2/\text{cm}^3$. The higher particles surface concentrations in premises were detected by the activities with copying/printing, poor ventilation and carpets.
- The study of dust particle surface area evaluation of indoor air <u>TB-traheobronhial fraction</u> (from 250 1000 nm) indicates that "the cleanest or the reference room" mean was $1.5 \,\mu\text{m}^2/\text{cm}^3$ and the highest $15.2 \,\mu\text{m}^2/\text{cm}^3$.
- The concentrations of *particle count* were in range from 1060 till 30 000 particles/m³.




Results: Particles concentration of Alveolar fraction during printing/copying process (lack of ventilation)




🔞 RSU_kop_2diena_ist ... LV 📾

Results: Particles Count during printing/copying process (lack of ventilation)




Results— measures of particles (3)

Surface area measurements of alveolar fraction



Measurements of **particle count**



The peak concentrations of particles surface area and count concentrations are similar in the same time!

Concentrations of Particles and Status of Ventilation

Status of Ventilation	Parameters	Min average value	Max average value	Average value	STDEV
Lack of ventilation systems	Alveolar fraction, μm²/cm³	46.6	55.0	50.8	5.9
	Tracheobronhial fraction, µm²/cm³	13.2	15.2	14.2*	1.4
	Particle count , number/m³	9700.0	14756.0	12228.0*	3575.1
Mechanical ventilation system in-flow/out-flow	Alveolar fraction, μm²/cm³	11.7	55.5	29.7	15.8
	Tracheobronhial fraction, µm²/cm³	2.4	13.0	5.2*	3.1
	Particle count , number/m³	3150.0	9570.0	6161.4*	2208.5

^{*} Statistically significant (p<0.05)



Concentration of Particles and Printing/Copying Activities

Printing/copying activities	Parameters	Min average value	Max average value	Average value	STDEV
Less than 1000 pages per day	Alveolar fraction, µm²/cm³	6.0	54.9	25.3	15.5
	Tracheobronhial fraction, $\mu m^2/cm^3$	1.5	15.2	5. 0	3.8
	Particle count, number/m³	1880.0	14756.0	5628.4*	3736.1
More than 1000 pages per day	Alveolar fraction, μm²/cm³	23.4	55.5	40.9	16.8
	Tracheobronhial fraction, $\mu m^2/cm^3$	4.2	13.2	8.8	5.0
	Particle count, number/m³	6462.0	9700.0	8493.3*	1506.1

^{*} Statistically significant (p<0.05)



Results – IAQ measures – EI>1

Chemicals	EI>1	Chemicals	EI>1
Acetaldehyde	100%	Butilacetate	0%
Formaldehyde	60,3%	Toluene	0%
Propilaldehyde	39,7%	Hydrocarbons (total by C)	8,5%
Butilaldehyde	20,4%	NO ₂	9,5%
Benzaldehyde	5,8%	SO ₂	14,3%
Ethanol	0%	O_3	62,5%
Etilacetate	58,1%	CO ₂	58,3%

Acceptable level for acetaldehyde – 0,01 mg/m³, but for formaldehyde – 0,1 mg/m³!



Results – microclimate measures


- ■Relative humidity, %: from 12,3 to 49,1%, in 55,6% cases humidity were < 30% (norms: from 30 to 70%).
- ■Air temperature, °C: from +19,1 to +25,5 °C (norms: from +19,0 to +25,0 °C in winter season and from +20,0 to +28,0 °C in summer season).
- Air velocity, m/s: from **0 to 0,04 m/**s (norms: from 0,05 to 0,15 m/s).



Results – **survey**

■ Females - 86% (N=774) un males - 14% (N=121)

■ Age:



■ Lenght of service: from 2 month to 47 years.



Results – survey – Odds ratio (1)

If workers observe:

- Low humidity (dry air), then:
 - sore, dry throat OR=1,5 (95% TI 1,1 2,2)
 - dry skin OR=2.5 (95% TI 1.8 3.6)
- **High air temperature**, then:
 - dry and itchy eyes OR=1,6 (95% TI 1,1-2,3)
 - fatigue OR=1,5 (95% TI 1,0-2,3)



Results – survey – Odds ratio (2)


■ If workers observe

Unpleasant odor smell, then:

- headache OR=1,5 (95% TI 1,0 2,3)
- fatigue OR=2,3 (95% TI 1,5 3,5)
- nausea or feeling sick -2.5 (95% TI 1.3 4.3)
- dizziness OR=1,9 (95% TI 1,0 3,6)
- cough OR=1,5 (95% TI 1,1-2,0).

Results – correlations (1)


The positive complaints about difficulties to concentrate and CO_2 concentrations in the premises.





Results – correlations (2)


The positive complaints about **fatigue** and CO_2 concentrations in the premises.





Results – correlations (3)

■ The positive complaints about **headaches** and **CO**₂ concentrations in the premises.





Conclutions

■ The main indoor air quality indicators are CO₂, total volitale organic compounds (also aldehydes), microclimate parameters, dust particle concentration (by surface area and count).

Multifactorial analyse show relations between indoor air quality indicators and health complaints among office workers.

■ Long-term and systematic impact of poor non-industrial indoor air can cause health complaints of office workers.



Acknowledge

Project Nr. EEZ09AP-22 "Determination of indoor air pollution caused by offices equipment and estimation of possible impact on organism"

Thank You for Your Attention!



